

Model 193A Voltage Detector Test Plug

The 193A Test Plug is used to verify that the Foreign Voltage Detector (FVD) is working properly. The 193A has a built-in voltage divider and current limiter circuit.

Testing the FVD on a 193A Voltage Detector Test Plug

- A. Press and hold the FVD power switch and touch the FVD probe tip to the contact point of the test plug that is plugged into an electrical wall outlet (120V).
- B. The test plug should activate the audible alarm and cause 6 or 7 steps of the bar graph to illuminate.
- C. If the alarm fails to activate when testing with the test plug, replace the FVD.

Ordering Information:

Model 193A Voltage Detector Test Plug



Model 193A

Telco Sales, Inc.®

118 Hilltop Business Drive
Pelham, AL 35124

Telephone: 205-403-0113

Fax: 205-403-0119

E-mail: sales@telco-sales.com

www.telco-sales.com